

25X1A9a

DEC 3 1953

25X1A9a

ADDITIONAL ELECTRICAL WORK IN OUR AUXILIARY BUILDING WILL BE APPROVED
IN AMOUNT OF \$260.83 WITH UNDERSTANDING THAT SWITCHES SHALL BE
SEPARATELY ENCLOSED SAFETY SWITCHES, TYPE C OR D, TWO POLE SOLID
NEUTRAL, FUSIBLE, QUICK BREAK, OR HEAVY DUTY 20 AMP TUMBLER
SWITCHES.

03/2143Z